



15 Britton Dr.  
 Bloomfield, CT 06002  
 (860) 953-1231

**WORK ORDER**

ORDER #: <b>1243170</b>
----------------------------

CUSTOMER PO: 93754663

DATE: 10/10/2024

CLIENT LOCATION: City of New Haven  
 Wilbur Cross High School  
 181 Mitchell Drive  
 New Haven , CT 06511

BILLED TO:  
 City of New Haven  
 200 Orange Street  
 Bureau of Purchases  
 New Haven , CT 06510

DESCRIPTION: Wilbur Cross High School, New Haven CT - Leak  
 CALL TYPE: 199 - NTE - CT  
 WORK PERFORMED: 10-9-24 - Arrived on site and checked in with maintenance to investigate the leak reported. On the roof, we found 2 open corners, 1 open lap and 1 puncture. We cleaned, primed, patched and caulked. We cleaned up and checked out.

ASSIGNMENTS				
EMPLOYEE NAME	DATE	TRAVEL TIME (MINS)	DETAILS	TOTAL HOURS
		0		
		0		

PARTS		
QUANTITY	PART NUMBER	DESCRIPTION
0.00	--	VENDOR#55015
0.25	114007	Firestone Splice/Membrane Wash
1.00	114002	Firestone Quick Prime
1.00	114003	Firestone Lap Sealant Caulk
0.15	110003	Firestone-Quick Seam 5" Flashing
1.00	190065	Rags
1.00	1300	Miscellaneous Materials
9.36	1095	Labor

LABOR	
QUANTITY	DESCRIPTION

IS JOB COMPLETE? **Yes**

**Customer:**

Date: 10/09/2024

**Employee:** Carmelo Santiago Perez

Date: 10/09/2024 12:11PM

TERMS AND CONDITIONS

*\*Note: Additional travel charges may accrue after you have signed this work order.*

